ENVIRONMENTAL LABWORKS, INC.

June 21, 2024

Mr. Steve Rossi
Wallkill Central School District
1580 Route 208
Wallkill, NY 12589

Dear Mr. Rossi,

The following are results of the analyses performed on water samples from **Leptondale Elementary School – Mill St., Wallkill, NY** received at the laboratory on 06/04/24.

```
Date/Time Collected:  06/04/24 5:44-5:57am First Draw
Collected By:         UC BOCES
Project ID:           06042419
Secondary ID:         WK242047-57
```

| LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Kitchen veg sink 06042419-1	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Kitchen double sink right 06042419-2	EPA 200.8 Lead	0.0020 mg/L	0.005 mg/L	06/13/24
Kitchen double sink left 06042419-3	EPA 200.8 Lead	0.0014 mg/L	0.005 mg/L	06/13/24
Cafeteria fountain 06042419-4	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Cafeteria bottle filler 06042419-5	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Flagpole fountain 06042419-6	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Flagpole bottle filler 06042419-7	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Bathroom upstairs fountain 06042419-8	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24

ENVIRONMENTAL LABWORKS, INC.

Leptondale Elementary School - 06042419

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Bathroom upstairs bottle fill 06042419-9	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Library fountain 06042419-10	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Library bottle filler 06042419-11	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24

The data contained in this report were obtained using EPA or other approved
methodologies. This laboratory or any outside laboratory used are NYSDOH
certified for these analyses. Vendor laboratory used was ELAP #11549. The
results in this report apply to the samples received by the laboratory, analyzed
in accordance with the chain of custody document. This analytical report may
only be reproduced in its entirety.

Thank you,

for Michael F. Lupi
Technical Director