

ENVIRONMENTAL LABWORKS, INC.

June 21, 2024

Mr. Steve Rossi
Wallkill Central School District
1500 Route 208
Wallkill, NY 12589

Dear Mr. Rossi,

The following are results of the analyses performed on water samples from **Ostrander Elementary School - 137 Viola Ave., Wallkill, NY** received at the laboratory on 06/04/24.

Date/Time Collected: 06/04/24 6:12-6:25am First Draw
Collected By: UC BOCES
Project ID: 06042420
Secondary ID: WK242058-68

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Kitchen double sink right 06042420-1	EPA 200.8 Lead	0.0036 mg/L	0.005 mg/L	06/13/24
Kitchen double sink left 06042420-2	EPA 200.8 Lead	0.0044 mg/L	0.005 mg/L	06/13/24
Veg sink 06042420-3	EPA 200.8 Lead	0.0014 mg/L	0.005 mg/L	06/13/24
Cafeteria fountain 06042420-4	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Cafeteria bottle filler 06042420-5	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Gym fountain 06042420-6	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Gym bottle filler 06042420-7	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Courtyard fountain 06042420-8	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824


ENVIRONMENTAL LABWORKS, INC.

Ostrander Elementary School - 06042420

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Courtyard bottle filler 06042420-9	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Bathroom fountain 06042420-10	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24
Bathroom bottle filler 06042420-11	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/13/24

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director