

ENVIRONMENTAL LABWORKS, INC.

June 28, 2024

Mr. Steve Rossi
Wallkill Central School District
1500 Route 208
Wallkill, NY 12589

Dear Mr. Rossi,

The following are results of the analyses performed on water samples from **Wallkill High School** received at the laboratory on 06/07/24.

Date/Time Collected: 06/07/24 5:31-6:36am First Draw
Collected By: UC BOCES
Project ID: 06072402
Secondary ID: WH242165-83

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Kitchen island sink 06072402-1	EPA 200.8 Lead	0.0028 mg/L		0.005 mg/L	06/19/24
Kitchen kettle faucet 06072402-2	EPA 200.8 Lead	0.0245 mg/L	X	0.005 mg/L	06/19/24
Kitchen double sink right 06072402-3	EPA 200.8 Lead	0.0015 mg/L		0.005 mg/L	06/19/24
Kitchen double sink left 06072402-4	EPA 200.8 Lead	0.0024 mg/L		0.005 mg/L	06/19/24
Cafeteria fountain 06072402-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Cafeteria bottle filler 06072402-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
New wing fountain 06072402-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
New wing bottle filler 06072402-8	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Faculty fountain 06072402-9	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Faculty bottle filler 06072402-10	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24

ENVIRONMENTAL LABWORKS, INC.

Wallkill High School - 06072402


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
New wing upstairs fountain 06072402-11	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
New wing upstairs bottle filler 06072402-12	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Faculty upstairs fountain 06072402-13	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Faculty upstairs bottle filler 06072402-14	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Bathroom upstairs fountain 06072402-15	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Bathroom upstairs bottle filler 06072402-16	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Auditorium bottle filler 06072402-17	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Main hall fountain 06072402-18	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24
Main hall bottle filler 06072402-19	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/19/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director