

## ENVIRONMENTAL LABWORKS, INC.

---

June 28, 2024

Mr. Steve Rossi  
Wallkill Central School District  
1500 Route 208  
Wallkill, NY 12589

Dear Mr. Rossi,

The following are results of the analyses performed on water samples from **Wallkill Middle School** received at the laboratory on 06/07/24.

Date/Time Collected: 06/07/24 6:03-6:25am First Draw  
Collected By: UC BOCES  
Project ID: 06072403  
Secondary ID: WM242184-200

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Kitchen double sink right 06072403-1	EPA 200.8 Lead	0.0027 mg/L	0.005 mg/L	06/19/24
Kitchen double sink left 06072403-2	EPA 200.8 Lead	0.0045 mg/L	0.005 mg/L	06/19/24
Veg sink 06072403-3	EPA 200.8 Lead	0.0029 mg/L	0.005 mg/L	06/19/24
Cafeteria fountain 06072403-4	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
Cafeteria bottle filler 06072403-5	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
Main office fountain 06072403-6	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
Main office bottle filler 06072403-7	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
Cafeteria in fountain 06072403-8	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
Cafeteria in bottle filler 06072403-9	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
208 side fountain 06072403-10	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24


## ENVIRONMENTAL LABWORKS, INC.

Wallkill Middle School - 06072403

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
208 side bottle filler 06072403-11	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
208 side upstairs fountain 06072403-12	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
208 side upstairs bottle filer 06072403-13	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
Faculty upstairs fountain 06072403-14	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
Faculty upstairs bottle filler 06072403-15	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
3 <sup>rd</sup> floor fountain 06072403-16	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24
3 <sup>rd</sup> floor bottle filler 06072403-17	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	06/19/24

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director